

DATE: _____

COMPANY: _____


JOB NAME: _____

SUBMITTED BY: _____

NOTES: _____

**DROP BOX FLEX DUCT CONCENTRIC KIT
SUBMITTAL DATA FOR:
CARRIER UNITS
48GS 018-042; 48GX, 024-036; 50JS,
JZ 018-042; 48/50 XP 024-036;
45/50 SD 024-036; 50 SZ 024-030
SEE ALSO BRYANT UNITS**

BRYANT UNITS
574A 024-030;
574B 024-036;
583A 024-036;
582ANW 018-042;
601A, 701A 018-042;
602A, 602B, 702A,
702B 024-036;
604A, 704A 024-030;
604B, 704B 024-036;
604C, 704C 024-030



FEATURES:

CONCENTRIC PANS ARE INSULATED INTERNALLY AND SHIPPED ASSEMBLED

CONCENTRIC BOX IS CONSTRUCTED OF GALVANIZED STEEL AND IS INSULATED INTERNALLY

LOWER BOX IS FACTORY PAINTED WHITE

CONCENTRIC BOX AND DIFFUSER GRILLE ARE SHIPPED ASSEMBLED

SUPPLY GRILLES (TYP 4 SIDES)
EGG CRATE RETURN GRILLE IS ON THE BOTTOM

CAMBRIDGEPORT PART NUMBER	DUCT SIZE	APPLICABLE CURB MODEL NUMBERS	FLEX (SOLD SEPARATELY)	NOMINAL CFM	THROW IN FT.	
					MIN	MAX
1010277	2 @ 18"	CPRFCURB007A000P	1000080 (2-18")	600-1400	20	30

NOTES:

- 1 - INSTALL INSULATED ADAPTER PANS BEFORE A/C UNIT IS PLACED ON CURB.
- 2 - FIELD BAFFLES MAY BE REQUIRED FOR BALANCING
- 3 - CONCENTRIC BOX MUST BE FIELD SUPPORTED

Drawn By: CJT
Date: 02/28/08 Rev: 0
KML 1/7/10 Rev 1

Cambridgeport

AIR SYSTEMS

MEMPHIS, TN 38118

PHONE 1-877-648-2872 FAX 901-566-0035

SALISBURY, MA 01952

PHONE 1-800-648-2872 FAX 978-462-9189