

DATE: _____

COMPANY: _____

JOB NAME: _____

SUBMITTED BY: _____


NOTES: _____

**DROP BOX FLEX DUCT CONCENTRIC KIT
SUBMITTAL DATA FOR:**

CARRIER UNITS

**48GS 048-060; 48GX, 042-060; 50JS,
JZ 048-060; 48/50 XP 042-060; 45/50
SD 042-060; 50 SZ 036-060; 50JZ060
SEE ALSO BRYANT UNITS**

BRYANT UNITS
582ANW 048-060;
574A 036-060;
574B 036-060;
583B 042-060;
601A 048-060;
701A 042-060;
602A, 602B, 702A,
702B 042-060;
604A, 704A 036-060;
604B, 704B 036-060;
604C, 704C 036-060



FEATURES:

CONCENTRIC PANS ARE INSULATED INTERNALLY AND SHIPPED ASSEMBLED

CONCENTRIC BOX IS CONSTRUCTED OF GALVANIZED STEEL AND IS INSULATED INTERNALLY

LOWER BOX IS FACTORY PAINTED WHITE

CONCENTRIC BOX AND DIFFUSER GRILLE ARE SHIPPED ASSEMBLED

SUPPLY GRILLES (TYP 4 SIDES)
EGG CRATE RETURN GRILLE IS ON THE BOTTOM

CAMBRIDGEPORT PART NUMBER	DUCT SIZE	APPLICABLE CURB MODEL NUMBERS	FLEX (SOLD SEPARATELY)	NOMINAL CFM	THROW IN FT.	
					MIN	MAX
1010284	2 @ 18"	CPRFCURB009A00SL	1000080 (2-18")	1600-2000	20	30

NOTES:

- 1 - INSTALL INSULATED ADAPTER PANS BEFORE A/C UNIT IS PLACED ON CURB.
- 2 - FIELD BAFFLES MAY BE REQUIRED FOR BALANCING
- 3 - CONCENTRIC BOX MUST BE FIELD SUPPORTED

Drawn By: CJT
Date: 12/13/07 Rev: 0
KML 1/7/10 Rev 1

Cambridgeport

AIR SYSTEMS

MEMPHIS, TN 38118

PHONE 1-877-648-2872 FAX 901-566-0035

SALISBURY, MA 01952

PHONE 1-800-648-2872 FAX 978-462-9189