THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF CAMBRIDGEPORT AIR SYSTEMS. ANY REPRODUCTION IN PART OR WHOLE WITHOUT THE WRITTEN PERMISSION OF CAMBRIDGEPORT IS PROHIBITED.

	CAS No.	YEAR	Туре	Α	В	С	WGT
ЗА	1023736	2008-CURRENT	Enthalpy	17-1/2"	28-1/4"	20-5/8"	63lb
ЗА	N/A	PRE-2008	Enthalpy	17-1/2"	28-1/4"	20-5/8"	63lb
4A	1023737	2008-CURRENT	Enthalpy	23-1/4"	35-3/4"	16"	81lb
4A	N/A	PRE-2008	Enthalpy	23-1/4"	35-3/4"	16"	81lb
74A	1023738	2008-CURRENT	Enthalpy	22-1/4"	46-1/4"	21"	97lb
74A	N/A	PRE-2008	Enthalpy	22-1/4"	46-1/4"	21"	97lb

NOTE: THIS ECONOMIZER
USES THE FILTER ACCESS
PANEL SUPPLIED WITH THE
HVAC UNIT

NOTE: ECONOMIZERS COMPLY WITH
ASHRAE STANDARD 90.1-2013, TABLE
6.4.3.4.4, AND CALIFORNIA TITLE 24-2013
PRESCRIPTIVE SECTION 140.4 AND
MANDATORY SECTION 120.2

HVAC
unit filter

Note:

Ensure economizer

engages tabs in HVAC unit

REV A 11-2-16

Cambridgeport

HVAC Accessories & Engineered Systems
8 FANARAS DRIVE
SALISBURY, MA
800-648-2872

ESCRIPTION

CASECOMZR003AG\_, 004AG\_, 074AG\_ ULTRA LOW LEAK CONVERTIBLE

SIZE DWG. NO.

A ECONOMIZER SUBMITTAL SHEET

SHEET 1 OF 1

# SUBMITTAL

#### **CAMBRIDGEPORT ECONOMIZER**

#### CASECOMZR003AGE/ZIP/ULL

CARRIER UNITS 48/50 TC 004 - 007

BRYANT UNITS 548J, 558J, 580J 04-07 549J, 551J, 581J 04,05,06

#### CASECOMZR004AGE/ZIP/ULL

CARRIER UNITS 48/50 TC 008 - 014

BRYANT UNITS 558J, 580J 08, 09, 12, 14 551J, 581J 07, 08, 09, 12 548J 08, 09, 12 : 549J 07, 08, 09

### CASECOMZR074AGE/ZIP/ULL

CARRIER UNITS 48/50 HC14/TC16

#### Features:

BELIMO ZIP CONTROL SYSTEM, CALIFORNIA TITLE 24 CERTIFIED, FDD PRODUCT ID BZE1245

ECONOMIZER IS CONSTRUCTED OF 18 GAUGE GALVANIZED STEEL AND IS SHIPPED FULLY ASSEMBLED

**INCLUDES 90% BAROMETRIC RELIEF OPENING** 

STANDARD WITH ENTHALPY CONTROL AND BELIMO ENERGY MODULE FOR CO2 AND ACCESSORY ADD-ONS

ECONOMIZER IS GEAR DRIVEN AND CONVERTIBLE

MOISTURE ELIMINATING FILTERS

WIRING HARNESS AND ENTHALPY SENSOR FACTORY INSTALLED (SOME FIELD WIRING MAY APPLY)

ALL NECESSARY HARDWARE AND INSTRUCTIONS INCLUDED

5 YEAR WARRANTY FROM SHIP DATE ON PARTS AND COMPONENTS

SLOPED WEATHERHOOD AND BLOCK-OFF PANEL COLOR MATCHED TO HVAC UNIT.

## APPROVAL

Submitted to:
Company:

Job Name:

Equipment:

Approved by:

Date: