

Cambridgeport

SUBMITTAL

Part Number
2001433

SUBMITTED TO _____
 COMPANY _____
 JOB NAME _____
 EQUIPMENT _____
 SIGNATURE _____
 DATE _____

© 2013/04/20 ENGINEERING DEPT. CAMBRIDGEPORT AIR SYSTEMS. THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO COV ENGINEERING COMPANY DBA CAMBRIDGEPORT AIR SYSTEMS. THE DOCUMENT OR THE INFORMATION CONTAINED IN WHOLE OR IN PART MAY NOT BE REPRODUCED TO ANOTHER PARTY WITHOUT WRITTEN CONSENT AND ALTERATION FROM CAMBRIDGEPORT.

SUBMITTAL

REVISIONS			
ZONE	REV.	DESCRIPTION	DATE APPROVED

NOTE: TOTAL ESTIMATED PRESSURE DROP 3/4" WG

Approved By: _____
Date: _____

FEATURES:

1. ONE PIECE WELDED CONSTRUCTION
2. CURB ADAPTER MADE OF HEAVY GAUGE GALVANIZED STEEL.
3. ALL WELDS ARE COATED WITH A GALVANIZED COMPOUND.
4. GASKETING IS PROVIDED FOR UNIT TO CURB ADAPTER SEALING.
5. CURB ADAPTER IS FULLY INSULATED.
6. SUPPLY AND RETURN PLENUMS INCLUDED.
7. BLANK-OFF PANEL SHIPPED LOOSE FOR FIELD INSTALLATION.

Cambridgeport		4 CARLETON DRIVE GEORGETOWN, MA 01833 1-800-648-2872 1-978-465-8481	
HVAC Accessories & Engineered Systems			
UNLESS OTHERWISE SPECIFIED	CUST. NO.	DRAWN	PRG
TOLERANCES:	CUT. NO.	DATE:	DESCRIPTION:
DIMENSIONS - ±.015	CON. NO.	2/01/22	ASS'Y, ADAPTER
ANGLES - ±1°	JOB NO.		
MATERIAL CONDITIONS:	SUBMITTAL		
REMOVE ALL BURRS & SHARP EDGES	NO.		
ALL DIMENSIONS ARE OD	DETAIL OF	SHEET 1	REV.
	2001433	of 1	2001433

MATERIAL: 14GA.(0.0785) 1135.8 LBS.

FEATURES

- ONE PIECE WELDED CONSTRUCTION
- FACTORY INSTALLED SUPPLY TRANSITIONS
- FULLY INSULATED
- DESIGNED FOR EVEN WEIGHT DISTRIBUTION
- FABRICATED OF HEAVY GAUGE G90 GALVANIZED STEEL
- ALL WELDS SPRAYED WITH GALVANIZING COMPOUND
- GASKET PROVIDED FOR UNIT TO ADAPTER SEALING

CAMBRIDGEPORT STRONGLY RECOMMENDS CONFIRMING THE DIMENSIONS ON THIS SUBMITTAL

CURB ADAPTERS ARE BASED ON UNIT MANUFACTURERS STANDARD CURB DIMENSIONS.
 CAMBRIDGEPORT CANNOT BE RESPONSIBLE FOR ANY DEVIATIONS FROM FACTORY DIMENSIONS OR INCORRECT MODEL NUMBERS.